



We help ideas meet the real world



# Compliance Statement

No. 2009-083

## Unscreened Connecting Hardware, Category 5e

### Company

ADC Communications (UK) Ltd.  
Runnings Road  
Kingsditch Trading Estate  
Cheltenham, Gloucestershire GL51 9NQ  
England

### Product description

Unscreened Category 5e connecting hardware characterised up to 100 MHz, 100  $\Omega$

- ADC KRONE Category 5e 24 port UTP PCB patch panel: 6527 1 607-24
- ADC KRONE Category 5e 48 port UTP PCB patch panel: 6527 1 630-00
- ADC KRONE Category 5e 12 port UTP MiniLAN PCB patch panel: 6527 1 003-00

### Product identification

ADC KRONE part number: 6526 2 021-xx, where 'xx' denotes the number of modular ports per PCB assembly

### Generic cabling standards, cabling components standard

- ISO/IEC 11801 2<sup>nd</sup> edition:2002
- EN 50173:2007
- ANSI/TIA/EIA-568-B.2

### Technical report

DELTA-N312566-05, DANAK-19J2046

### Manufacturer code

1161A

### Certificate valid until

6 October 2010

This product has been tested by EC Cabling Group of DELTA and complies with the electrical requirements of the above specified standards and "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The testing included measurement of NEXT with all the 9 test cases using test plugs characterised with the de-embedded technique as specified in ANSI/EIA/TIA-568-B.2. The product takes part in a maintenance of certification schedule, which implies that EC Cabling performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis once a year.

Hørsholm, 6 April 2009

Erik Bech  
Test Manager

Claude Videt  
Project Manager

DELTA

Venlighedsvej 4  
2970 Hørsholm  
Denmark

Tel. +45 72 19 40 00  
Fax +45 72 19 40 01  
www.delta.dk/cable

