



Certificate

Customer: ADC KRONE
Beeskowdamm 3-11
D-14167 Berlin-Zehlendorf, Germany

Description: **ADC KRONE TrueNet[®] CAT.7 Horizontal Cable
S/FTP LSZH AWG23**

Part-No.: 7053 3 762-55
7053 3 062-54 (Duplex)

Applied standards: ISO/IEC 11801: 2002-09
Information technology – Generic cabling for customer premises
EN 50173-1: 2002
Information technology – Generic cabling systems Part 1
prEN 50288-4-1: 2002
Multi-element metallic cables used in analogue and digital communication and control; Part 4: Sectional specification for screened cables characterised up to 600 MHz; Section 1: Horizontal and building backbone cables, shielded) - 2003

Comments: Up to a bandwidth of 600 MHz the sample meet the limits of the specified standards and regulations with respect to the parameters indicated above.

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the data cables or connectors are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, **no. P1772b-07-E, from November 15th 2007** and shall only be applicable in conjunction with the test report.

Bexbach, November 15th 2007

Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG
In der Kolling 13
D-66450 Bexbach
Phone: +49 (0) 68 26 / 92 28 – 0
Fax: +49 (0) 68 26 / 92 28 – 99
E-Mail: info@ghmt.de
<http://www.ghmt.de>

